

# Rhino EQ-300® Whole House Water Filtration System

## Performance Data Sheet; Chlorine, Taste & Odor Reduction

This system has been tested by Underwriters Laboratories according to ANSI/NSF Standard 42 for the reduction of the substances listed below. The concentration of the indicated substances in water entering the system was reduced to a concentration less than or equal to the permissible limit for water leaving the system as specified in NSF/ANSI Standard 42

Sample Points (effluent samples taken)	Substance; Chlorine Influent Concentration Allowable Range 2ppm +/- 10% (before filter)	Effluent Chlorine Concentration (after filter)	Percent Reduction Of Chlorine Minimum allowable reduction is >= 50%
(Gallons Filtered)	(Parts Per Million)	(Parts Per Million)	(7 Gallons/Minute Flow Rate)
<b>Initial Sample</b>	2 ppm	<0.01 ppm	>99%
30,000 gal.	2 ppm	<0.01 ppm	>99%
60,000 gal.	2 ppm	<0.01 ppm	>99%
90,000 gal.	2.1 ppm	<0.01 ppm	>99%
120,000 gal.	2 ppm	<0.01 ppm	>99%
150,000 gal.	2.2 ppm	<0.01 ppm	>99%
180,000 gal.	2.1 ppm	<0.01 ppm	>99%
210,000 gal.	2.1 ppm	<0.01 ppm	>99%
240,000 gal.	1.9 ppm	<0.01 ppm	>99%
270,000 gal.	2.1 ppm	<0.01 ppm	>99%
300,000 gal.	2 ppm	<0.01 ppm	>99%

**Operating Pressure Range; 20-100 psi**

**Rated Service Flow; 7 Gallons Per Minute**

**Rated Pressure Drop; 11 psi**

**Operating Temperature Range; 40° to 90° F**

**Filtration Capacity; 300,000 Gallons**

Testing was performed under standard laboratory conditions, actual performance may vary.

**Call 763-291-8342 to Order Now and Secure Your \$200 Discount and Free Shipping**